



GOVT OF ARUNACHAL PRADESH
PHE & WS DEPT
PASIGHAT SUB DIVISION
EAST SIANG, ARUNACHAL PRADESH

No. AEP/PHE/E-19/2018-19/12


Dated: 25/06/2024


WATER QUALITY TEST REPORT

OF

MOUNT CARMEL ENGLISH SCHOOL, PASIGHAT, BALEK ROAD, EAST SIANG DISTRICT, AP.

<i>S/no</i>	<i>1</i>	<i>Acceptable range</i>
Name of source	Lifting	
Date of sample collection & test	25/06/2024	
Turbidity	0.0	5.0
Ph value	6.75	6.5 – 8.5
Total hardness mg/L	15.0 mg/L	200
Total iron mg/L	0.15 mg/L	0.3
Chloride mg/L	1.1 mg/L	250.00
Nitrate mg/L	0.21 6 mg/L	45.00
Flouride mg/L	0.60 mg/L	1.5
Suplhate mg/L	2.0 mg/L	200
Total Alkanity	35 mg/L	200
Manganese	0.01 mg/L	0.3
TDS	59.0 ppm	500
Bactriological test	Negative	0


Lab. Assistant
PHE & WS Sub Division


25/06/24
Assistant Engineer
PHE & WS Sub Division
Pasighat